



OAKLAND FIRE DEPARTMENT INSPECTION RECORD



BT

S

Block # _____

Bus Lic. # _____

ADDRESS _____ BUSINESS NAME _____

MANAGER/OWNER _____ PHONE # _____ FAX # _____

A reasonable degree of fire safety exists at this time. (Date) _____ (Inspector Number) _____

In accordance with Section 103.4.3.1 of the California Fire Code you are hereby ordered to correct all violations immediately upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court.

S-1 S-2 S-3 S-4 S-5 OCCUPANCY DESCRIPTION _____

GENERAL SAFETY REQUIREMENTS

- 077 Provide address numbers plainly visible and legible from the street of contrasting color to their background.
- S-5F Keep dumpsters 5 feet from combustible walls, openings, and combustible roof eave lines.
- S-6F Post and maintain NFPA 704 placards that are plainly visible on the exterior of the building
- A-3D Oily rags & similar materials shall be stored in metal, metal-lined or other approved containers with tight-fitting lid.
- S-3B Storage not permitted in boiler rooms, mechanical rooms, electrical panel rooms.
- S-6G Maintain minimum of 18" from ceilings of sprinklered bldg. or 24" from ceilings in non-sprinklered buildings. (ex. along walls)
- A-5B Combustibles are to be kept a minimum of 18" from heating appliances.
- S-5G Fire assemblies shall be maintained in working condition. Interlocks on dust producing equipment and dust collecting machinery.

EXITING REQUIREMENTS

- H4-2A Two exits required if occupant load exceeds 50 or H-4 occupancies 1000 square feet or larger.
- S-2A Exits shall not be obstructed in any manner
- S-5H All locking devices shall be of an approved type.
- S-2B Exit doors shall be maintained in an operable condition at all times.
- S-2C Exit doors shall swing in the direction of exit travel when serving any hazardous area.
- S-2D Exit paths shall be illuminated when the building or structure is occupied.
- S-2F Exit signs shall be installed at required exits and where otherwise necessary to clearly indicate direction of egress.
- S-2G When the exit way is not easily identified, additional exit signs may be required.
- S-2H Exit signs shall be internally or externally illuminated at all times by two lamps or shall be of the self-luminous type.

FIRE PROTECTION EQUIPMENT

- S-1A Minimum of one 4-A:40-B:C extinguisher shall be easily accessible so that travel distance does not exceed 50'. Extinguishers shall be mounted in plain view between 3'-5' from the floor.
- S-1C Extinguishers shall be serviced annually and shall have a current service tag attached.
- S-5C Where an automatic or manual fire alarm system is in place, such system shall be maintained in operating condition.
- S-5D Where an automatic extinguishing system is in place, such systems shall be serviced and maintained in operating condition. (Inspected/serviced quarterly; re-certified every 5 years for fire sprinklers)
- 041 All fire sprinkler systems over 100 heads shall be continuously monitored by a UL listed central monitoring company.
- S-6A Provide fire sprinkler coverage to all areas of the building. Plans &/or permits (may/will) be required.

ELECTRICAL REQUIREMENTS

- S-4A Extension cords shall not be used as a substitute for permanent wiring.
- S-4C Appliance cords shall be kept in good condition with no splices.
- S-4D A clear depth of 36" and height of 78" shall be maintained from the face of electrical switchboards and panel boards.
- S-6B Electrical main control panels and sub-panels shall be labeled as to the area served.
- S-6C Doors into electrical control rooms shall be marked with a plainly visible/legible sign "ELECTRICAL ROOM".
- S-6D Repair, replace, correct electrical hazards of wiring, outlets, cover plates, circuit breakers or other devices.
- _____ Class 1, Division 1 explosion proof minimum required electrical.

PERMITS ARE REQUIRED OR COMPLIANCE WITH POSTED PERMIT.

- P-C.7 To store, use or handle compressed gases.
- H4-6A To use a structure as a place of business for serving or repairing motor vehicles.

MISC. REQUIREMENTS

- S-6E Racks with storage over 8' high must be installed with a building permit and engineered securing system.
- _____
- _____
- _____
- _____
- _____

An inspection to determine if you have complied with this order will be conducted on or about ___/___/____. If you have further questions contact the undersigned Inspector at phone # _____.

1st Insp. ___/___/___ Owner/Mgr. _____ Inspector (print) _____

2nd Insp. ___/___/___ Owner/Mgr. _____ Inspector (print) _____

3rd Insp. ___/___/___ Owner/Mgr. _____ Inspector (print) _____